


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 1075 / 28.06.2010**

| | | | |
|---------------|-------------|-------------|-----------------------|
| NUMBER | 1075 | DATE | 28 / 06 / 2010 |
|---------------|-------------|-------------|-----------------------|

| | |
|-----------------------------|--|
| Client' s data: | ALUMINCO S.A. ALUMINIUM SYSTEMS THESE MEGALI RAHI GR 320 11 INOFYTA VIOTIAS GREECE |
| Product description: | DOUBLE SASH WINDOW SLIDING |
| Material: | ALUMINIUM |
| System : | AL 220 |



1560 x 1360 mm

| | |
|--|-----------------|
| Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i> | Class 2 |
| Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i> | Class 1B |
| Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i> | Class C4 |

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOPI PAPAPOPOULOU
LABORATORY MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL