


SUMMARY OF RESULTS

OF TESTING CERTIFICATE 0906 / 10.02.2009

NUMBER	0906	DATE	10 / 02 / 2009
---------------	-------------	-------------	-----------------------

Client' s data:	ALUMINCO S.A. ALUMINIUM SYSTEMS THESI MEGALI RAHI GR 320 11 INOFYTA VIOTIAS GREECE
Product description:	DOUBLE SASH DOOR SLIDING
Material:	ALUMINIUM
System :	AL 250



2200 x 1440 mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 3A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C4

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOPI PAPAPOPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL