


**SUMMARY OF RESULTS  
OF TESTING CERTIFICATE 1089 / 01.09.2010**

<b>NUMBER</b>	<b>1089</b>	<b>DATE</b>	<b>01 / 09 / 2010</b>
---------------	-------------	-------------	-----------------------


<b>Client' s data:</b>	<b>ALUMINCO S.A.</b> <b>ALUMINIUM SYSTEMS</b> THESE MEGALI RAHI GR 320 11 INOFYTA VIOTIAS GREECE
<b>Product description:</b>	<b>DOUBLE SASH WINDOW</b> <b>TILT / TURN</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>AL 410</b>



1550 x 1350 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 4</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 3A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C3</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOPI PAPAPOPOULOU**  
**LABORATORY MANAGER**



**IOANNIS GKERTSOS**  
**GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL