


SUMMARY OF RESULTS OF TESTING CERTIFICATE 0812 / 21.02.2008

NUMBER	0812	DATE	21 / 02 / 2008
---------------	-------------	-------------	-----------------------

Client' s data:	ALUMINCO S.A. ALUMINIUM SYSTEMS THESEI MEGALI RAHI GR 320 11 INOFYTA VIOTIAS GREECE
Product description:	DOUBLE SASH WINDOW OPENING
Material:	ALUMINIUM
System :	AL 520



1220 x 950 mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 7A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C5

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOPI PAPADOPOULOU
TECHNICAL MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL